



DECLARATION OF PERFORMANCE

according to

- Construction Products Regulation 305/2011/ EC

No.: 02CPR2013-06-28

- Product: **Sounder**
- Type: **BExS110D (24Vdc), BExS120D (24Vdc)**
- Intended for use in accordance with the applicable harmonised technical specification in:

Fire detection and fire alarm systems in and around buildings

- Manufacturer:

Pfannenberg GmbH
Werner-Witt-Str. 1
21035 Hamburg - Germany
Tel. +49 40 73412-0
Fax: +49 40 73412-345
Email: info@pfannenberg.com

- Name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2) :

Nils-Peter Halm
Werner-Witt-Str. 1
21035 Hamburg - Germany
Tel. +49 40 73412-219
Fax: +49 40 73412-102
Email: nils.halm@pfannenberg.com

- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 2+

- Notified Certification Body: VdS, 0786
EC-Certificate of Conformity: 0786-CPD-20225

- Declared performance:

Essential Characteristics	Performance	Harmonized Standard
Operational reliability	Pass	EN 54-3:2001 / A1:2002
Performance under fire condition	Pass	
Durability of operational reliability, temperature resistance	Pass	
Durability of operational reliability, corrosion resistance	Pass	
Durability of operational reliability, shock and vibration resistance	Pass	
Durability of operational reliability, electrical stability	Pass	
Durability of operational reliability, resistance to ingress	Pass	

- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

Signed for and on behalf of the manufacturer by:

Hamburg, June 2013

Rev.Nr.00

Peter Obermann

Managing Director